

PURCHASING DEPARTMENT/WAREHOUSE

Katherine Mendoza
Purchasing /Warehouse Manager
1001 West Roger Road, Tucson, AZ 85705
(520) 696-3713 • kmendoza@amphi.com

701 W. Wetmore Road • Tucson, AZ 85705 • (520) 696-5000 • www.amphi.com

GOVERNING BOARD MEMBERS

SUPERINTENDENT
Todd A. Jaeger, J.D.

Vicki Cox Golder
President

Deanna M. Day, M.Ed.
Vice President

Scott K. Baker, Ph.D.

Susan Zibrat

Matthew A. Kopec

October 7, 2022

RE: IFB Canyon Del Oro HS N Gym HVAC Conversion 1042022CDO

Below are questions/answers for the above referenced RFQ. All other terms and conditions remain the same.

- 1) The following shall be incorporated in the contract documents of the above project, and all requirements herein are fully a part of the contract documents.

Documents Issued : Drawings

END OF AMENDMENT FOUR IFB 1042022CDO

Amphitheater High • Canyon del Oro High • Ironwood Ridge High
Amphitheater Middle School • Coronado K-8 School • Cross Middle School • La Cima Middle School • Wilson K-8 School
Copper Creek Elementary • Donaldson Elementary • Harelson Elementary • Holaway Elementary • Innovation Academy • Keeling Elementary
Mesa Verde Elementary • Nash Elementary • Painted Sky Elementary • Prince Elementary • Rio Vista Elementary • Walker Elementary • Rillito Center • Amphi Academy Online

Amphitheater Unified School District does not discriminate on the basis of race, color, religion/religious beliefs, gender, sex, age, national origin, sexual orientation, creed, citizenship status, marital status, political beliefs/affiliation, disability, home language, family, social or cultural background in its programs or activities and provides equal access to the Boy Scouts and other designated youth groups. Inquiries regarding the District's non-discrimination policies are handled at 701 W. Wetmore Road, Tucson, Arizona 85705 by David Rucker, Equity & Safety Compliance Officer and Title IX Coordinator, (520) 696-5164, drucker@amphi.com, or Kristin McGraw, Executive Director of Student Services, (520) 696-5230, kmcgraw@amphi.com.



Amendment 1
Amphitheater Public School
17.14.73 CDO High School – North Gym HVAC Replacement

AMENDMENT ONE – Date: October 7, 2022

The following Amendment shall be incorporated in the Contract Documents of the above project, and all requirements herein are fully a part of the Contract Documents.

DOCUMENTS ISSUED:

Attachment 1 – Sheet A2.1 Reflected Ceiling Plan

Attachment 2 – Sheet A2.2 Roof Plan

Attachment 3 – Sheet A10.1 Roof Details


Attachment 4 – Mechanical Note

DRAWINGS:

1. Clarification: Sheet A2.1 – ceiling patch work is removed, all work associated with structural detail 4 is removed from scope
2. Clarification: Sheet A2.2 – roof patch work is removed. (E) curbs to remain.
3. Clarification: Sheet A10.1 – detail 5 removed, detail 11 added, detail 4 modified
4. Clarification: Sheet M4.1 – note addition

BID-WALK QUESTIONS:

1. Refer to attached RFI log for answers



END OF AMENDMENT ONE

Construction General Notes

1. COORDINATE ALL WORK BETWEEN ARCHITECTURAL, STRUCTURAL, MECHANICAL, AND ELECTRICAL DRAWINGS. CONTRACT SHALL BE RESPONSIBLE TO THE ATTENTION OF THE ARCHITECT PRIOR TO BEGINNING WORK.
2. REFERENCES INDICATED CEILING PLAN FOR LAYOUT AND CLIMATE ANTENNA UNIT, REFERENCE MECHANICAL AND ELECTRICAL DRAWINGS FOR FINAL AND COMPANION.

Construction Keynotes

- ① MECHANICAL KEYNOTES: SEE MECHANICAL EQUIPMENT REMOVAL, HATCH (E) PROFILE AND COLOR.
- ② MECHANICAL EQUIPMENT: SEE MECHANICAL.
- ③ STRUCTURAL: SEE STRUCTURAL.


Brocktonridge
 ARCHITECTS
 1735 S. H. Lowell Rd. #12
 Tucson Arizona 85719
 520.882.9944

Amplifier for Public Schools
 Canyon del Oro High School
 North Gym HVAC Conversion



Project No. 171475
 Date: MAY 2022
 Revision: 1
 Description: HVAC Conversion
 Drawn By: [Signature]
 Checked By: [Signature]
 Approved By: [Signature]
 Title: [Title]
 Date: [Date]

Reflected Ceiling Plan
A2.1



Reflected Ceiling Plan
 1/8" = 1'-0"




1. REMOVE MECHANICAL COMPONENTS TO EXAMINE, USE, REPAIR OR DISPOSE OF PROPERLY. REMOVE FACTOR AND STAYING FOR WIND UPST AND TO MEET EXACTLY AS CONSTRUCTION AND WATER LINES, CUT BELOW BODY UNTIL CONTACT WITH EXISTING CONDUIT. REMOVE EXISTING CONDUIT AND REPAIR OR REPLACE EXISTING CONDUIT AND WATER LINE.
2. ACCESS LADDER, IN STRUCTURAL
3. DAVIT CHAIR, IN STRUCTURAL
4. EXISTING CHAIR.
5. POOR WEAR, IN MECHANICAL

Albuquerque Public Schools
Canyon del Oro High School
North Gym HVAC Conversion




17,14.73
MAY 2022


[illegible]A2.2
Roof Plan




Typical Coating Section





Equipment Curb




Duct Penetration




Cant

[illegible]


Not Used




Pipe Flashing




Flashing at Crane Pedestal




Disconnect Mount





GateSection




Flashings at Roof Hydrant




Curb Capping







KELLY · WRIGHT
& ASSOCIATES · PC
HVAC · PLUMBING
FIRE PROTECTION



ADDENDUM

KWA Addendum #:	1	Date:	October 3, 2022
Project:	CDO North Gym HVAC Conversion	KWA Project #:	21030
Architect:	Breckenridge Group	Architect's Project #:	17.14.73
Owner:	Amphitheater Public School District	Owner IFB#:	1042022CDO

This addendum is issued before award of contract to inform the bidders of clarifications, revisions and additions to the bidding documents. All requirements contained in the bidding documents shall apply to this addendum, and the general character of the work called for in this addendum shall be the same as originally set forth in the applicable portions of the bidding documents for similar work, unless otherwise specified under this addendum, and all work shall be included in the bids, even though not particularly mentioned in this addendum. Prior approval reviews are based on general compliance with project intent and do not constitute approval. This addendum is hereby made a part of the bidding documents and shall be included in the contract.

REFER TO DRAWINGS:

1. Drawing M4.1, Rooftop Packaged Heat Pump Schedule: ADD note to 'complete with' column as follows: "FIELD INSTALLED – CONTRACTOR PROVIDED ITEMS: Construct enclosure made of cladded, closed cell elastomeric type insulation sheets equivalent to Armacell "Arma-Tuff", to fully enclose portions of the evaporative coil which are exposed outside the unit cabinet in the condenser section. Intent is to encapsulate the cold surfaces to prevent condensation outside the condensate pan. Insulation shall be joined using the manufacturer's contact adhesive (tape is not allowed) to make vapor-tight. Seal to unit casing to make vapor-tight and weather proof."

END OF ADDENDUM

